



Product Service

ZERTIFIKAT

Nr. Z2B 10 06 11176 404

Zertifikatsinhaber: **Hugo Brennenstuhl GmbH & Co KG**
 Seestr. 1-3
 72074 Tübingen
 DEUTSCHLAND

Prüfzeichen:



Produkt: **Mehrfachsteckdosen
 4-fach Steckdoseneinsatz**

Das Produkt wurde auf freiwilliger Basis auf die Einhaltung der grundlegenden Anforderungen geprüft und kann mit dem oben abgebildeten Prüfzeichen gekennzeichnet werden. Eine Veränderung der Darstellung des Prüfzeichens ist nicht erlaubt. Die Übertragung eines Zertifikates durch den Zertifikatsinhaber an Dritte ist unzulässig. Umseitige Hinweise sind zu beachten.

Prüfbericht Nr.: 028-71369900-000

Datum, 2010-06-17

(Helmut Ludwig)

Seite 1 von 2



TÜV SÜD Product Service GmbH
 Zertifizierstelle
 Ridlerstr. 65 · 80339 München
 Germany



DEUTSCHES
 AKKREDITIERUNGSSYSTEM
 PRÜFWESEN GMBH



DAP-ZE-1213.00



Product Service

ZERTIFIKAT

Nr. Z2B 10 06 11176 404

Modell(e): 402-11
- mit oder ohne Temperaturschalter
- mit oder ohne Kinderschutz

Marke: BAT

Kenndaten:

Nennspannung:	250 V~
Nennstrom:	16 A
Schutzklasse:	I
Schutzart:	IP 20 (muss durch den Einbau sichergestellt werden)

Geprüft nach: DIN VDE 0620-1:2010
IEC 60884-1/A1:2006

**Produktions-
stätte(n):** 67424

Seite 2 von 2

TÜV SÜD Product Service GmbH
Zertifizierstelle
Ridlerstr. 65 · 80339 München
Germany



DEUTSCHES
AKKREDITIERUNGSSYSTEM
PRÜFWESEN GMBH



DAP-ZE-1213.00



Product Service

CERTIFICATE

No. Z2B 10 06 11176 404

Holder of Certificate: Hugo Brennenstuhl GmbH & Co KG

Seestr. 1-3
72074 Tübingen
GERMANY

Certification Mark:



Product:

**Multiple sockets
4-times socket outlet**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

028-71369900-000

Date, 2010-06-17

(Helmut Ludwig)

Page 1 of 2



TÜV SÜD Product Service GmbH
Zertifizierstelle
Ridlerstr. 65 · 80339 München
Germany

TÜV®

DEUTSCHES
AKKREDITIERUNGSSYSTEM
PRÜFWESEN GMBH

DAP

DAP-ZE-1213.00

ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFICATO ◆ CERTIFICATE ◆ 認証証書 ◆



Product Service

CERTIFICATE
No. Z2B 10 06 11176 404

Model(s): **402-11**
- with or without thermal cut-out
- with or without shutter

Brand Name: **BAT**

Parameters:

Rated voltage:	250 V~
Rated current:	16 A
Protection class:	I
Protection against moisture:	IP 20 (must be guaranteed by the installation)

Tested according to: DIN VDE 0620-1:2010
IEC 60884-1/A1:2006

Production Facility(ies): 67424

Page 2 of 2

TÜV SÜD Product Service GmbH
Zertifizierstelle
Ridlerstr. 65 · 80339 München
Germany



DEUTSCHES
AKKREDITIERUNGSSYSTEM
PRÜFWESEN GMBH



DAP-ZE-1213.00